



K-GAS

EMERGENCY PROCEDURES

GAS LEAK WITH FIRE

- 1> **Evacuate immediate area**
- 2> *Call 000 and advise of LPG leak and give container type and size*
- 3> **Shut of Gas Supply – IF SAFE**
- 4> *If this is not possible, leave the gas to burn and cool with water from a safe distance, unless the fire impinges on the LPG container or threatens to cause property damage, do not extinguish burning gas.*
- 5> **LPG containers are fitted with safety relief valves which may allow a discharge of LPG when the LPG container is subject to heat. If safe to do so, fix a fine water spray and exit the area.**
- 6> *If heating of the LPG Cylinder is intense, the container may rupture. DO NOT approach an LPG container suspected of being hot*
- 7> **Where possible, remove unaffected LPG Container from path of fire and keep LPG container cool**
- 8> *Never use an LPG container which has been involved in a fire situation*